

# Water level in Skorradalur lake & flow below the Andakílsá Hydropower Station 2018

In 2018 the goal of keeping the flow below the Andakílsá Hydropower Station within limits to ensure it is no less than 2 m<sup>3</sup>/s was achieved to safeguard the river's ecosystem and salmon, despite the environmental incident in the spring of 2017.

Apart from parts of March and October, water level fluctuation targets in Lake Skorradalvatn were met and within the limits, which are 1.08 m in normal operations in the winter and 0.4 m in the summer.

