

Release from Veitur utilities' sewerage system 2014-2018

In 2018, the discharge of wastewater via overflows in the capital area was within Veitur Utilities' established limits. Under Regulation no. 798/1999 on Sewerage systems and Sewage, overflow in the sewerage system may be active for up to 5% of the year, or when the sewage mixed with hot water from district heating utilities or rainwater is at least on a ratio of 1:5. The emergency overflow in Skeljanes and Gufunes were active for 1.7% of the year each, which is not in accordance with Veitur Utilities' objectives, that emergency overflows should remain inactive.

